LIFE SCIENCES



RSV Pressure Transmitter



The Anderson RSV Pharmaceutical Series Pressure Transmitter offers not only a new low profile design, but may be ordered with built-in LCD indication. The unit meets all pharmaceutical requirements for performance, finish and cleanability. It is designed and manufactured to withstand the harsh process and sterilization conditions encountered in the pharmaceutical and biotechnology industries.

Its one-piece stainless steel package design incorporates a transducer and electronic circuitry to convert pressure and/or vacuum to a proportional 4-20 mA signal. The wide variety of fittings and ranges provide flexibility in specifying the best transmitter for any application. The unit is designed to operate at high process temperatures and withstand CIP/ SIP conditions.

All units are supplied factory calibrated to standard or custom ranges. For field maintenance, non-interactive zero, and span adjustments, as well as field accessible test points are provided. The optional LCD cap mounted display can be scaled to match actual process units, 0-100% of full scale, or 4-20 mA. This useful feature provides indication directly at the process, in addition to the standard 4-20 mA output. Permanently marked tagging is provided at no extra charge. In addition the RSV complies with Class 1, Div. 1, Groups A, B, C and D for intrinsically safe apparatus. Units are supplied with certificates of calibration.

SPECIFICATIONS

Excitation:

9-32 VDC (Absolute), 24 VDC Nominal regulated or unregulated 14-37 VDC (Absolute) with display

Output:

4-20 mA DC

Loop Resistance:

0-750 ohms at 24 VDC 0-1050 ohms at 30 VDC

Indication:

Optional, 3 1/2 digit, .5" high LCD, cap mounted

Accuracy:

± 0.5% of span, full scale, for standard ranges except those below
0-50 psig (±1.0% full scale. All vacuum/pressure ranges and PSIA ranges are ±1.0%)

Over-Range Rating:

2 times base range

Stability:

± 0.3% of calibrated range / 6 months

Zero and Span Adjustments: ± 10% of range

Repeatability: ± 0.3%

Hysteresis: ± 0.1%

Linearity:

± 0.1%

Process Temperature Range: 20° to 275°F (Up to 325°F if horizontal mount)

Process Temperature Effect:
± 0.1 psig/5.5°C (10°F)
Ambient Temp. Operating Range: -17.8° to 48.9°C (0° to 120°F)
Storage Temperature:
-40° to 65°C (-40° to 149°F)
Mounting:
Direct connection
Housing Material:
304 Stainless Steel
Housing Ratings:
NEMA 4X, IP66
Wetted Parts:
316L Stainless Steel standard; Hasteloy "C"
diaphragm optional
Surface Finish (wettable parts):
$R_a max = 8$ microinches (.2 microns) electropolished
Recommended Cable:
18-24 AWG, foil shielded, and PVC coated.
(3/16 - 1/4 OD insulation)
Wiring Connection:
Screw Terminal; Accessible via removable screw
cap conduit housing
Approvals:
UL Approved; Complies with Class 1, Div. 1, Grps. A-D for
intrinsically safe apparatus Standard:
Designed and manufactured to sound engineering
practices in accordance with Article 3.3 of the PED 97/23/EC
Response Time:
200 µSec
* Specifications are subject to change without notice.

Complete Product Ordering Matrix

RANGE CABLE LENGTH	
025 30/0 (M) 028 30"Hg/0/15 psig (C) 029 30"Hg/0/30 psig (C) 031 30"Hg/0/100psig (C) 032 30"Hg/0/100psig (C) 066 0/30 (G, A) 068 0/50 (G, A, B) 071 0/100 (G, A) 073 0/150 (G, A) 074 0/160 (G, A) 074 0/160 (G, A) 074 0/160 (G, A) 074 0/160 (G, A) 084 0/1000 (G) 084 0/1000 (G) 084 0/1000 (G) 286 -1/0/2.5 BAR (B) 217 -1/0/3 BAR (B) 235 0-3 BAR (B) 235 0-3 BAR (B) 235 0-3 BAR (B) 235 0-20 BAR (B) 065 0-20 BAR (B)	
ENGINEERING UNITS G PSIG (Gauge) M Hg (inches Mercury - Vacuum) A PSIA (Absolute) B BAR (Gauge) C Vacuum/Pressure Compound (Hg & PSIG) T BAR (Absolute)	
FITTING 002 3/4" Tri-Clamp® 004 1 1/2" Tri-Clamp® 005 2" Tri-Clamp® 005 2" Tri-Clamp® 010 1 1/2" APC "K" 011 2" APC "K" 016 1 1/2" Cherry "I" (male) 017 2" Cherry "I" (male) 028 2" G & H "H" Line (male) 123 Anderson "CPM" Flushmount	
DISPLAY VALUE 0 None G PSIG A PSIA B BAR R mA (milliamphere, for vac/press.) Q % (percent, for vac/press.)	
DIAPHRAGM MATERIAL 1 316L Stainless 2 Hastelloy "C"	NC
DIAPHRAGM FINISH ANDERSON INSTRUMENT CO., 156 Auriesville Road 2 Electropolished (Ra8) Futionville, NY 1027 USA 3 SPECIFY TAGGING INFORMATION TO BE SPECIFY TAGGING INFORMATION TO BE PERMANENTLY MARKED, IF APPLICABLE SPECIFY TAGGING INFORMATION TO BE PERMANENTLY MARKED, IF APPLICABLE NEGELE MESSTECHNIK Gmb (A Division of Anderson) Rafifeisenweg 7 D-B7743 Egg a. (Dair of Control and Part Part Part Part Part And Part Part Part Part Part Part Part Part	997 LP ada 52 H Y 9204-49

Form AIC 3562 © 2/04 Revised: December 2008 Supercedes: July 2008